

**UOBWA AWIA Risk and Resilience Assessment RFP**

**Answers to Questions**

08.19.20

**Q:** Will UOBWA accept proposals from IT consulting firms for the cybersecurity assessment portion of the AWIA Risk and Resilience Assessment/Emergency Response Plan only?

**A:** No, proposals must be submitted and stamped by a certified civil engineer.

08.19.20

**Q:** Because there is no “engineering” or “design” work involved in the AWIA process, would UOBWA / NGRC consider setting aside this requirement?

**A:** No, the requirement will remain, and reports must be stamped by a GA Licensed Engineer.

08.21.20

**Q:**

1. Can you provide the population served by the UOBWA including populations of wholesale customers?

**A:** UOBWA serves four wholesale customers. Wholesale customer population sizes may be found by querying the EPA Water System ID (WSID) database here: <https://www.epa.gov/enviro/sdwis-search>

- ~~2. Does the UOBWA maintain a distribution system? **No.** If yes please provide the following:  
a. ~~Approximately how many miles of distribution mains are maintained?~~  
b. ~~How many storage tanks are maintained?~~  
c. ~~How many booster pump stations?~~  
d. ~~How many pressure zones are in the system?~~~~
3. How many treatment plants are in operation?

**A:** One

4. How many source water withdrawal permits does the Authority have?

**A:**

<b>List of Georgia EPD UOBWA Surface Water Withdrawal Permits (Revised April 2018)</b>						
<b>River Basin</b>	<b>Surface Water Withdrawal Permit Holder</b>	<b>Surface Water Withdrawal Permit Number</b>	<b>County</b>	<b>Source</b>	<b>Permit Limit Max Day (Million Gallons/Day)</b>	<b>Permit Limit Monthly Average (Million Gallons/Day)</b>
Oconee	Upper Oconee Basin Water Authority	<b>078-0304-06</b>	Jackson	Bear Creek Reservoir	79.000	58.000
Oconee	Upper Oconee Basin Water Authority	<b>078-0304-05</b>	Jackson	Middle Oconee River	60.000	60.000